

## Emergency Lighting Systems

NOTE: Reference is made to the latest / revised version of the standard,\*\* denotes as amended

Classification in this category is intended for those Enterprise/Member undertaking the installation of emergency lighting systems.

Classification in this category may be achieved if the Enterprise/Member:

- Has publications and documentation appropriate to the range and scale of work undertaken which **must** include the following:
  - a) BS 5266-1: \*\*, Emergency Lighting - Code of practice for the emergency lighting of premises.

Additional appropriate documentation may include (BS EN 1838: \*\* Lighting Applications – Emergency Lighting.

- Will undertake that all work is carried out by competent persons to a standard not less than that laid down in BS 5266 including appropriate verification and shall conform with the requirements of BS 7671 and the Electricity at Work Regulations 1989.
- Has at least one nominated competent person who has the necessary skills and experience to carry out the work to the appropriate standards and meets the requirements for a nominated Qualified Supervisor in work category 3.1 for Low and Extra-low Voltage Electrical Installations up to 1kV.